

**Certificate of compliance** 

Applicant:	Sunova Solar Technology Co., Ltd		
	Building E, Phase II, Standard Workshop, Runzhou Road, Huishan Industrial		
	Transformation and Agglomeration Area, Wuxi, Jiangsu Province,		
	P.R. China, 214000		
Product:	Photovoltaic (PV) and battery inverter		
Model:	SUNOVA-TL 5K-EU-D		
	SUNOVA-TL 6K-EU-D		
	SUNOVA-TL 8K-EU-D		
	SUNOVA-TL 10K-EU-D		
	SUNOVA-TL 12K-EU-D		

Inverter for three-phase parallel connection to the public grid. The network monitoring and disconnection device is an integral part of the above-mentioned model.

### Applied rules and standards:

### EN 50549-1:2019

Requirements for parallel connection of installations with distribution networks - Part 1: Connection to an LV distribution network - Production of installations up to and including Type B

- 4.4 Normal operating range
- 4.5 Immunity to disturbances
- 4.6 Active response to frequency deviation
- 4.7 Power response to voltage variations and voltage changes
- 4.8 EMC and power quality
- 4.9 Interface protection
- 4.10 Connection and starting to generate electrical power
- 4.11 Ceasing and reduction of active power on set point

4.13 Requirements regarding single fault tolerance of interface protection system and interface switch

## DIN VDE V 0124-100:2020 (5.5.2.1 Functional safety of network and system protection)

Grid integration of generator plants - Low-voltage - Test requirements for generator units to be connected to and operated in

parallel with low-voltage distribution networks

## Commission Regulation (EU) 2016/631 of 14 April 2016

Establishing a network code on requirements for grid connection of generators (NC RFG).

Type approval for generation units to use in Type A and Type B plants.

At the time of issue of this certificate, the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number:	ASUE-ESH-P23031028	Certification Program:	NSOP-0032-DEU-ZE-V01
Certificate number:	U23-0273	Date of issue:	2022-04-06
		Certification body	
	N		DAKKS Deutsche Aktreditierungsstelle
	8 4 7	Georg Loritz	D-ZE-12024-01-00
Certification	body Bureau Veritas Consumer Pi	oducts Services Germany GmbH accreditation to I	DIN EN ISO/IEC 17065
	Testing laboratory a	ccredited according to DIN EN ISO/IEC 17025	
A partial represen	ntation of the certificate requires the	e written approval of Bureau Veritas Consumer Pro	ducts Services Germany GmbH



Appendix

Extract from test report acco	No.	No. ASUE-ESH-P23031028				
Type Approval and declarati 2016/631 of 14 April 2016	on of compliance with the	e requirements of EN 5	0549-1 and Commissio	n Regulation (EU)		
Manufacturer / applicant	Sunova Solar Technology Co., Ltd					
	Building E, Phase II, Standard Workshop, Runzhou Road, Huishan Industrial					
	Transformation and Agglomeration Area, Wuxi, Jiangsu Province,					
	P.R. China, 214000					
••• · •						
Micro-generator Type	Photovoltaic and battery	rinverter				
	SUNOVA-TL 5K-EU-D	SUNOVA-TL 6K-EU-D	SUNOVA-TL 8K-EU-D	SUNOVA-TL 10K-EL D		
PV Input voltage range		160-800 Vdc				
MPPT Input range	200-650 Vdc					
PV input current	13A+13A 26A+13A					
Battery voltage range	40-60Vdc					
Max. charge current	120A	150A	190A	210A		
Max. discharge current	120A	150A	190A	210A		
Rated grid voltage	3L/N/PE 400V, 50Hz/60Hz					
Max. AC Output current	8,0A	9,6A	12,8A	15,9A		
AC Output Rated. current	7,2A	8,7A	11,6A	14,5A		
Rated active Power	5kW	6kW	8kW	10kW		
Max. apparent Power	5,5kVA	6,6kVA	8,8kVA	11kVA		
	SUNOVA-TL 12K-EU- D					
PV Input voltage range	160-800 Vdc					
MPPT Input range	200-650 Vdc					
PV input current	26A+13A					
Battery voltage range	40-60Vdc					
Max. charge current	240A					
Max. discharge current	240A					
Rated grid voltage	3L/N/PE 400V, 50Hz/60Hz					
Max. AC Output current	19,1A					
AC Output Rated. current	17,4A					
Rated active Power	12kW					
Max. apparent Power	13,2kVA					
Firmware version	V1090					

The power generation unit is equipped with a PV and line-side EMC filter. The power generation unit has no galvanic isolation between DC input and AC output. Output switch-off is performed with single-fault tolerance based on the inverter bridge and two series-connected relays in each line and neutral. This enables a safe disconnection of the power generation unit from the network in case of error.



# Appendix

## Extract from test report according to EN 50549-1

No. ASUE-ESH-P23031028

### Note:

The settings of the interface protection are password protected adjustable.

In case the above stated generators are used with an external protection device, the protection settings of the inverters are to be adjusted according to the manufacturer's declaration.

The above stated generators are tested according to the requirements in the EN 50549-1:2019 Commission Regulation (EU) 2016/631 of 14 April 2016. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements.